

TEST REPORT OF GENERATOR SET'S PERFORMANCE

Model: SK-23000SE

Products consigned from: CHANGZHOU HI-EARNS MECHANICAL & ELECTRICAL CO.,TLD

HS CODE: 8502.11

NO	MODEL		①	②	③	④
	Inspect Item	Technique Requirement				
1	1200V,50HZ Withstand Voltage	Continue 60S not breakdown	OK	OK	OK	
2	Safety Protection Set	Reliable	OK	OK	OK	
3	Starting Performance	In 3 times	OK	OK	OK	
4	Rated Voltage(V)	检验 规范 规定	223.5	223.5	223.5	
5	Rated Frequency(Hz)		50.6	50.6	50.6	
6	Rated Power(W)		16.2	16.2	16.1	
7	Voltage wave rate(%)	≤1.5	0.7	0.7	0.7	
8	Frequency wave rate(%)	≤1	0.5	0.5	0.5	
9	Voltage stable adjust Rate(%)	≤7	3.6	3.6	3.6	
10	Frequency stable adjust rate(%)	≤6	2.4	2.4	2.4	
11	Leakproofness	No leakage	NO	NO	NO	
12	Stop reliability	Reliable	OK	OK	OK	
13	Direct Current (DC)	12~16V	14.5	14.5	14.5	
14	Conformity determination	√ qualified X unqualified	√	√	√	
Remark						

HRCY231212

Model: SK-23000SE

Insepector:

Wang

2023 Year 12 Month 20 Day



Only used for customs declaration

常州市海润机电有限公司
CHANGZHOU HI-EARNS MECHANICAL & ELECTRICAL CO., LTD.

茹文伟